

TESTREPORT
IEC 60502-1
Power cables with extruded insulation and their accessories
for rated voltages from 1kV up to 30 kV.

Report reference No.....: 2236358.51-CAT
Compiled by (+ signature): A.A. Mackenbach

Approved by (+ signature): R. van Daalen

Date of issue: 2019-08-22

Testing laboratory: DEKRA Certification B.V.

Address.....: Meander 1051, 6825 MJ Arnhem, The Netherlands

Testing location.....: as above

Applicant: National Cables Industry Sharjah U.A.E.

Address.....: Plot #6, between 7th and 8th interchange,

.....: PO Box 27472, Al Saja'a Industrial Area, Sharjah U.A.E.

Standards.....: IEC 60502-1:2004/A1:2009

Test Report Form No.: IEC 60502-1b

TRF originator.....: DEKRA

Master TRF: dated 2009-09

Type of test object.....: Cable

Trademark.....: NATIONAL CABLES INDUSTRY

Model/type reference: CU/XLPE/SWA/MDPE 4x150 mm²

Manufacturer: National Cables Industry Sharja U.A.E.

Rating: 0,6/1kV

Possible test case verdicts:

- test case does not apply to the test object: N(A)

- test object does meet the requirement.....: P(ass)

- test object does not meet the requirement: F(ail)

Remarks:

The tested cable meets the requirements.

TABLE OF CONTENTS

TABLE OF CONTENTS	2
1 Identification of the test object	3
1.1 Description of the test object	3
2 Conductors	5
2.1 Measurement of the resistance of the conductors.....	5
2.2 Measurement of the number of wires of the conductors	5
3 Electrical type tests	6
3.1 Measurement of XLPE insulation resistance at ambient temperature.....	6
3.2 Measurement of XLPE insulation resistance at max. conductor temperature in normal operation.....	7
3.3 Voltage test for 4 h.....	8
4 Non-electrical type tests	9
4.1 Measurement of thickness of XLPE insulation	9
4.2 Measurement of thickness of non-metallic sheaths	10
4.3 Tests for determining the mechanical properties of the XLPE insulation before and after ageing.....	11
4.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing.....	12
4.5 Additional ageing test on pieces of completed cables	13
4.6 Loss of mass test on PVC inner sheath of type ST ₂	14
4.7 Pressure test at high temperature on inner sheath.....	15
4.7.1 Pressure test at high temperature on oversheath type ST ₇	15
4.8 Test on PVC inner sheath at low temperatures.....	16
4.9 Test for resistance of PVC inner sheath to cracking (heat shock test).....	17
4.10 Hot set test for XLPE insulations	18
4.11 Water absorption test on XLPE insulations	19
4.12 Measurement of carbon black content of black MDPE oversheath.....	20
4.13 Shrinkage test for XLPE insulation	21
4.14 Shrinkage test for MDPE oversheaths	22
5 Verification of cable construction	23
6 Drawing	24

1 IDENTIFICATION OF THE TEST OBJECT

1.1 Description of the test object

Manufacturer	National Cables Industry
Type	CU/XLPE/SWA/MDPE
Year of manufacture	2019
Sampling procedure	By the manufacturer
Rated voltage, U_0/U (U_m)	0,6/1 kV
No. of cores	4
Marking on the cable	NATIONAL CABLES INDUSTRY U.A.E. 2019 600/1000 V 4X150 MM ² CU/XLPE/SWA/MDPE 0,6/1kV IEC 60502

Conductor

- material	Copper
- cross-section	150 mm ²
- type/shape of conductor	Shaped
- maximum conductor temperature in normal operation	90 °C

Insulation

- material	XLPE
- nominal thickness	1,4 mm
- core identification	Red, yellow, blue, black

Inner covering

- type	Extruded
- material	PVC
- nominal thickness	1,4 mm

Filling material

Polypropelene yarns

Binder tape

Polypropelene

Metallic armour

- material Galvanized steel wires
- nominal diameter / dimensions 46,9 mm, ø 2,5 mm

Oversheath

- material MDPE, type ST,
- nominal thickness 2,6 mm
- outer diameter of cable 52,0 mm
- colour Black

Fire retardant

Not claimed

2 CONDUCTORS

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 5
Test date 16 July 2019

2.1 Measurement of the resistance of the conductors

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
- resistance	Ω/km	≤ 0,124	0,116	0,117	0,116	0,116

Result

The object passed the test.

2.2 Measurement of the number of wires of the conductors

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
- number of wires	-	≥ 18	37	37	37	37

Result

The object passed the test.

3 ELECTRICAL TYPE TESTS

3.1 Measurement of XLPE insulation resistance at ambient temperature

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 17.1

Test date 19 July 2019

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
volume resistivity, ρ at 20 °C	$\Omega \cdot \text{cm}$	–	$3,1 \cdot 10^{17}$	$3,0 \cdot 10^{17}$	$2,5 \cdot 10^{17}$	$2,5 \cdot 10^{17}$
insulation resistance constant, K_i at 20 °C	$M\Omega \cdot \text{km}$	–	$11,5 \cdot 10^5$	$11,0 \cdot 10^5$	$9,1 \cdot 10^5$	$9,2 \cdot 10^5$

Result

The test results are for information only.

3.2 Measurement of XLPE insulation resistance at max. conductor temperature in normal operation

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 17.2
Test date 22 July 2019

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
volume resistivity, ρ at 90 °C	$\Omega \cdot \text{cm}$	$\geq 10^{12}$	$2,2 \cdot 10^{16}$	$1,6 \cdot 10^{16}$	$1,9 \cdot 10^{16}$	$1,5 \cdot 10^{16}$
insulation resistance constant, K_i at 90 °C	$M\Omega \cdot \text{km}$	$\geq 3,67$	$8,1 \cdot 10^3$	$5,8 \cdot 10^3$	$6,9 \cdot 10^3$	$5,4 \cdot 10^3$

Result

The object passed the test.

3.3 Voltage test for 4 h

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 17.3
Test date 22 July 2019

Environmental conditions

Temperature 20 ± 2 °C

applied voltage (kV)	frequency (Hz)	duration (h)	measured/determined
2,4	50	4	no breakdown

Requirement

No breakdown of the insulation shall occur.

Result

The object passed the test.

4 NON-ELECTRICAL TYPE TESTS

4.1 Measurement of thickness of XLPE insulation

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.1

Test date 23 July 2019

insulation thickness	unit	requirement	specified	measured/determined			
				Red	Yellow	Blue	Black
- nominal	mm	1,4	1,4	-	-	-	-
- average	mm	-	-	2,2	2,4	2,1	2,0
- minimum (t_m)	mm	$\geq 1,16$	$\geq 1,16$	1,83	1,74	1,81	1,67

Result

The object passed the test.

4.2 Measurement of thickness of non-metallic sheaths

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.2
Test date 23 July 2019

Inner sheath

thickness	unit	requirement	specified	measured/determined
- nominal	mm	$\geq 1,2$	$\geq 1,4$	-
- average	mm	-	-	1,9
- minimum (t_{min})	mm	$\geq 0,92$	-	1,68

Oversheath

thickness	unit	requirement	specified	measured/determined
- nominal	mm	$\geq 1,8$	2,6	-
- average	mm	-	-	2,9
- minimum (t_{min})	mm	$\geq 1,88$	-	2,08

Result

The object passed the test.

4.3 Tests for determining the mechanical properties of the XLPE insulation before and after ageing

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.3
 Test period 22 July 2019 until 5 August 2019

Characteristic test data

Temperature during ageing 135 ± 3 °C
 Duration 7 days

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
without ageing						
- tensile strength	N/mm ²	≥ 12,5	22,8	24,5	24,9	24,2
- elongation	%	≥ 200	536	581	579	557
after ageing						
- tensile strength	N/mm ²	-	24,8	27,8	23,3	24,6
- variation with samples without ageing	%	± 25 max.	9	13	-6	2
- elongation	%	-	568	589	562	566
- variation with samples without ageing	%	± 25 max.	6	1	-3	2

Result

The object passed the test.

4.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.4
Test period 22 July 2019 until 5 August 2019

Characteristic test data (inner sheath)

Temperature during ageing 100 ± 2 °C
Duration 7 days

Inner sheath

item	unit	requirement	measured/determined
without ageing			
- tensile strength	N/mm ²	$\geq 12,5$	13,5
- elongation	%	≥ 150	367
after ageing			
- tensile strength	N/mm ²	$\geq 12,5$	13,0
- variation with samples without ageing	%	± 25 max.	-4
- elongation	%	≥ 150	338
- variation with samples without ageing	%	± 25 max.	-8

Characteristic test data (oversheath)

Temperature during ageing 110 ± 2 °C
Duration 10 days

Oversheath

item	unit	requirement	measured/determined
without ageing			
- tensile strength	N/mm ²	$\geq 12,5$	32,8
- elongation	%	≥ 300	760
after ageing			
- tensile strength	N/mm ²	-	29,8
- variation with samples without ageing	%	-	-9
- elongation	%	≥ 300	769
- variation with samples without ageing	%	-	1

Result

The object passed the test.

4.5 Additional ageing test on pieces of completed cables

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.5
 Test period 18 July 2019 until 5 August 2019

Characteristic test data

Temperature during ageing 100 ± 2 °C
 Duration 7 days

Insulation

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
- tensile strength	N/mm ²	-	24,3	23,8	26,6	22,8
- variation with samples without ageing	%	± 25 max.	7	-3	3	-6
- elongation	%	-	543	545	570	539
- variation with samples without ageing	%	± 25 max.	1	-6	-2	-3

Inner sheath

item	unit	requirement	measured/determined
- tensile strength	N/mm ²	-	12,5
- variation with samples without ageing	%	± 25 max.	7
- elongation	%	-	348
- variation with samples without ageing	%	± 25 max.	-5

Oversheath

item	unit	requirement	measured/determined
- tensile strength	N/mm ²	-	31,1
- variation with samples without ageing	%	-	-5
- elongation	%	≥ 300	799
- variation with samples without ageing	%	-	5

Result

The object passed the test.

4.6 Loss of mass test on PVC inner sheath of type ST₂

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.6
Test period 25 July 2019 until 5 August 2019

Characteristic test data

Temperature during ageing 100 ± 2 °C
Duration 7 days

Inner sheath

item	unit	requirement	measured/determined
- loss of mass	mg/cm ²	≤ 1,5	0,1

Result

The object passed the test.

4.7 Pressure test at high temperature on inner sheath

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.7
Test date 31 July 2019

Characteristic test data

Temperature during ageing 90 ± 2 °C
Duration 6 h
Load 7,7 N

Inner sheath

item	unit	requirement	measured/determined
- depth of indentation	%	≤ 50	8

Result

The object passed the test.

4.7.1 Pressure test at high temperature on oversheath type ST₇

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.7
Test date 31 July 2019

Characteristic test data

Temperature during ageing 110 ± 2 °C
Duration 6 h
Load 10,4 N

Over sheath

item	unit	requirement	measured/determined
- depth of indentation	%	≤ 50	3

Result

The object passed the test.

4.8 Test on PVC inner sheath at low temperatures

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.8
Test period 22 July 2019 until 23 July 2019

Characteristic test data

Temperature -15 ± 2 °C
Period of application 16 h
Diameter of mandrel - mm
Number of turns -
Mass of hammer 1000 g

Inner sheath

item	unit	requirement	measured/determined
- cold bending test	-	no cracks	N/A
- cold elongation	%	≥ 20	125
- cold impact test	-	no cracks	no cracks

Result

The object passed the test.

4.9 Test for resistance of PVC inner sheath to cracking (heat shock test)

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.9
Test date 13 July 2019

Characteristic test data (inner sheath)

Temperature 150 ± 3 °C
Duration 1 h
Diameter of mandrel 4 mm
Number of turns 6

Inner sheath

item	unit	requirement	measured/determined
- soundness	-	no cracks	no cracks

Result

The object passed the test.

4.10 Hot set test for XLPE insulations

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.11
Test date 14 August 2019

Characteristic test data

Temperature 200 ± 3 °C
Time under load 15 min
Mechanical stress 20 N/cm²

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
- elongation under load	%	≤ 175	75	80	75	75
- permanent elongation	%	≤ 15	0	0	0	0

Result

The object passed the test.

4.11 Water absorption test on XLPE insulations

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.13
Test period 18 July 2019 until 8 August 2019

Characteristic test data

Temperature 85 ± 2 °C
Duration 14 days

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
- variation of mass	mg/cm ²	≤ 1	0,3	0,3	0,3	0,3

Result

The object passed the test.

4.12 Measurement of carbon black content of black MDPE oversheath

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.15
Test date 16 August 2019

item	unit	requirement	measured/determined
- carbon black content	%	2,5±0,5	2,2

Result

The object passed the test.

4.13 Shrinkage test for XLPE insulation

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.16
Test date 14 August 2019

Characteristic test data

Temperature 130 ± 2 °C
Duration 1 h

item	unit	requirement	measured/determined			
			Red	Yellow	Blue	Black
- shrinkage	%	≤ 4	2	2	2	2

Result

The object passed the test.

4.14 Shrinkage test for MDPE oversheaths

Standard and date

Standard IEC 60502-1 (2004) + Amd. 1 (2009), clause 18.20
Test period 22 July 2019 until 29 July 2019

Characteristic test data

Temperature 80 ± 2 °C
Duration 5 h
Heating cycles 5

item	unit	requirement	measured/determined
- shrinkage	%	≤ 3	2

Result

The object passed the test.

5 VERIFICATION OF CABLE CONSTRUCTION

Verification of cable construction was carried out in accordance with clauses 5-13 of IEC 60502-1. The results are presented below.

	observed/determined
marking on the cable	ROADS AND TRANSPORT AUTHORITY STREET LIGHTING 600/1000 V NATIONAL CABLES INDUSTRY U.A.E. 2019 4X150 MM ² CU/XLPE/SWA/MDPE 0,6/1kV IEC 60502
construction	<ul style="list-style-type: none">- conductor of copper wires sector shaped stranded- XLPE insulations (red, yellow, blue and black)- polypropylene filler and binder tape- innersheath of extruded PVC compound- armour of galvanized steel wires- outer sheath of extruded MDPE
outer diameter of the cable, average	54,5 mm

Result

No deviations from the specified requirements are found.

6 DRAWING

TECHNICAL & QC
DEPARTMENT

الوطني لصناعة الكابلات
NATIONAL CABLES INDUSTRY NCI


TECHNICAL DATA SHEET

Cable Size : 4x150 mm ²	Rated Voltage : 0.6/1 (1.2) kV	Cable Code: 0104042416R
Cable Type : CU/XLPE/SWA/MDPE	Ref. Standards : IEC 60502-1 & RTA Specs	

DIMENSION DATA:

S.NO	DESCRIPTION	UNIT	OFFER DETAILS
1	CONDUCTOR: Material Form of stranding Type of conductor D.C. Resistance at 20°C		Copper Sectoral Shaped Class 2 to IEC 60228 0.124
2	INSULATION: Material Thickness of insulation Colors	mm	Extruded XLPE 1.4 (Avg.) / 1.16 (Min.) Red, Yellow, Blue, Black
3	ASSEMBLY: Approximate diameter Fillers Binding tape	mm	39.1 Polypropylene yarns Polypropylene tape
4	INNER SHEATH: Material Thickness of inner sheath Approximate diameter	mm mm	Extruded PVC 1.4 (Nom.) / 0.92 (Min.) 41.9
5	ARMOUR: Material Wire diameter Approximate diameter	mm mm	Galvanized Round Steel Wire 2.5 46.9
6	OUTER SHEATH: Material Thickness of outer sheath Approximate overall diameter Color	mm mm	Extruded MDPE (Type ST7) 2.6 (Nom.) / 1.88 (Min.) 52.0 Black

DRAWING:



CABLE MARKING:

Embossing on the Outer Sheath in Max 50 cm Spacing along TWO lines :

First Line :

ROADS AND TRANSPORT AUTHORITY STREET LIGHTING, 600/1000 VOLTS

Second Line :

NATIONAL CABLES INDUSTRY, U.A.E., "YEAR", 4x150 mm², CU/XLPE/SWA/MDPE, 0.6/1 kV, IEC 60502

PACKAGING:

Approximate weight of complete cable	: 8175 kg/km
Nominal cutting length	: 500 m (± 5%)
Drum type	: Steel or Wooden
Drum dimensions (Approx.):	
• Outer diameter	: 2050 mm
• Outer width	: 1200 mm

All diameters and weights are approximate.

Prepared by: Naimuddin

Checked by: Rajasree

Approved by: Altaf Ahmed

P.O. Box: 27472 Sharjah, U.A.E. Tel: 06-5311888 Fax: 06-5311577

E-mail: n_c@emirates.net.ae Website: www.nci.ae

